

CAREL

Marchatura  /  labeling

Dichiarazione di conformità del Costruttore

/Manufacturer's declaration of conformity

Costruttore /Manufacturer: CAREL s.r.l. via dell'Industria, 11 BRUGINE (PD) ITALY

Project code	C409	Description	IR32 Universale Uscite O.C. PWM	Doc. Nu.	X409.07
--------------	------	-------------	---------------------------------	----------	---------

Product code	Description	Test plane	Standards	date
IR32D0L0xx	Termostato 1 uscita open collector sonda NTC <i>/ Thermostat 1 open collector.output NTC probe</i>	E409.15	EMC	30.01.97
IR32D1L0xx	Termostato 1 uscita open collector sonda Pt100 <i>/ Thermostat 1 open collector.output Pt100 probe</i>	E409.10	EN61000-3-2 EN61000-3-3	12.03.96
IR32D2L0xx	Termostato 1 uscita open collector sonda TC J/K <i>/ Thermostat 1 open collector.output TC J/K</i>	E409.11	EN55014 EN50082-1	12.03.96
IR32DbL0xx	Termostato 1 uscita open collector <i>/ Thermostat 1 open collector.</i>	E409.14		30.01.97
IR32A000xx	Termostato 4 uscite open collector sonda NTC <i>/ Thermostat 4 open collector outputs NTC probe</i>	E409.15	BT (LVD)	30.01.97
IR32A100xx	Termostato 4 uscite open collector sonda Pt100 <i>/ Thermostat 4 open collector outputs Pt100 probe</i>	E409.12	EN 60730-1 EN 60730-2-9	30.01.97
IR32A200xx	Termostato 4 uscite open collector sonda TC J/K <i>/ Thermostat 4 open collector outputs TC J/K</i>	E409.13		30.01.97
IR32Ab00xx	Termostato 4 uscite open collector <i>/ Thermostat 4 open collector outputs</i>	E409.14		30.01.97
Se IR=98	Display a led rossi e policarbonato frontale fornito da Carel srl. Se il policarbonato frontale è a cura del cliente deve essere eseguita una prova di verifica ESD specifica. <i>/Red led display and customized version using frontal label Carel made. If frontal label is customer made ESD test must be done for each customer.</i>	E409.04		09.11.95
b:	3=input 4÷20 mA, 4=input -0.5/ +1 Vdc			

Il costruttore dichiara che tutti i prodotti sopra descritti sono stati provati e risultano conformi alle norme indicate per verificare il rispetto dei requisiti essenziali richiesti dalle Direttive 89/336/CEE sulla compatibilità elettromagnetica (EMC), 73/23/CEE sulla sicurezza delle apparecchiature in bassa tensione (BT) e successive integrazioni.

/ The Manufacturer declares that all the products indicated complied with European standards listed above to verify the completely respect to essential requirements from 89/336/EEC (EMC), 73/23/EEC (LVD) and revisions.

October, 27 1997

CAREL s.r.l.
Technical Direction
Ing. Umberto Bianchini

