

# CAREL

Marcatura **CE** / *CE labeling*

## Dichiarazione di conformità del Costruttore

*Manufacturer's declaration of conformity*

Costruttore / *Manufacturer*: CAREL s.r.l. via dell'Industria, 11 BRUGINE (PD) ITALY

<i>Project code</i>	C409	<i>Description</i>	IR32 Universale	<i>Doc. Nu.</i>	X409.06
---------------------	------	--------------------	-----------------	-----------------	---------

Product code	Description	Test plane	Standards	date
IR32a0bcde	Termostato 1 relè sonda NTC / <i>Thermostat 1 relay NTC probe</i>	E360.02 E360.06	EMC	05.09.95 22.02.96
IR32a1bcde	Termostato sonda Pt100 / <i>Thermostat Pt100 probe</i>	E409.01 E409.05	EN61000-3-2 EN61000-3-3	02.10.95 22.02.96
IR32a2bcde	Termostato sonda TC J/K / <i>Thermostat J/K TC probe</i>	E409.02 E409.06	EN55014 EN50082-1	02.10.95 22.02.96
IR32a3bcde	Termostato input 4÷20 mA / <i>Thermostat input 4÷20 mA</i>	E409.03		02.10.95
IR32a4bcde	Termostato input -0.5/ 1 V / <i>Thermostat input -0.5/ 1 V</i>	E409.07		22.02.96
Se IR=98	Display a led rossi e policarbonato frontale fornito da Carel srl. Se il policarbonato frontale è a cura del cliente deve essere eseguita una prova di verifica ESD specifica. <i>/Red led display and customized version using frontal label Carel made. If frontal label is customer made ESD test must be done for each customer.</i>	E409.04	BT (LVD) EN 60730-1 EN 60730-2-9	09.11.95
a:	V=1relè, W=2 relè, Z=4 relè / <i>V=1 relay, W=2 relais, Z=4 relais</i>			
b:	Solo per versione V: E=no IR e Buzzer, L=12÷24 Vac, H=110÷240 Vac <i>/Only V version: E=no IR and buzzer, L=12÷24 Vac, H=110÷240 Vac</i>			
c:	iniziali cliente / <i>customer capital letter</i>			
d:	personalizzazione cliente / <i>personalized item</i>			
e:	=0 imballo singolo, =1 imballo multiplo <i>/=0 single package, =1 multiple package</i>			

Il costruttore dichiara che tutti i prodotti sopra descritti sono stati provati e risultano conformi alle norme indicate per verificare il rispetto dei requisiti essenziali richiesti dalle Direttive 89/336/CEE sulla compatibilità elettromagnetica (EMC), 73/23/CEE sulla sicurezza delle apparecchiature in bassa tensione (BT) e successive integrazioni.

*/ The Manufacturer declares that all the products indicated complied with European standards listed above to verify the completely respect to essential requirements from 89/336/EEC (EMC), 73/23/EEC (LVD) and revisions.*

October, 27 1997

CAREL s.r.l.  
Technical Direction  
Ing. Umberto Bianchini

